

Medium Voltage Switchgear

Table 5.0-A. Medium Voltage Switchgear Selector Guide

CAG Tab	Tab Title	Voltage Range	Switching Device	Drawout or Fixed	Front/Rear Accessible	Compartmentalized				Insulated Bus	ANSI Standards
						Breaker	Bus	Cable Area	VTs & CPTs		
5	Metal-Clad Switchgear— VacClad-W Medium Voltage Drawout Vacuum Breakers	4.76–38 kV	Vacuum breaker	Drawout	Front & rear required	■	■	■	■	■	C37.20.2
6	Metal-Enclosed Switchgear— MEF Front-Access Medium Voltage Drawout Vacuum Breakers	4.76–15 kV	Vacuum breaker	Drawout	Front only required	■			■	■	C37.20.2 & C37.20.3
7.1	Metal-Enclosed Switchgear— MEB Medium Voltage Drawout Vacuum Breakers				Front & rear required ①					②	C37.20.3
7.2	Metal-Enclosed Switchgear— MSB Medium Voltage Switch- and Fixed-Mounted Vacuum Breakers				Switch & vacuum breaker	Fixed				②	
8	Metal-Enclosed Switchgear— MVS Medium Voltage Load Interrupter Fusible Switch	4.76–38 kV	Fusible switches						②		

① Optional front access only designs available.
② Available as an option.



VacClad-W Metal-Clad Switchgear



MEB Metal-Enclosed Switchgear



MSB Metal-Enclosed Switchgear



MVS Load Interrupter Switchgear



MEF Switchgear (5–15 kV)

This page intentionally left blank.