



STRUCTURAL CALCULATIONS
FOR
SUSPENDED BUS SYSTEM SEISMIC SUPPORTS


SEISMIC SUPPORT GUIDELINES

PROJECT:

[Empty rectangular box for project details]

REVISION 0

Original Calculations Dated 05/30/17



CALCULATIONS PREPARED BY:




A. PALMA ENGINEERING
P.O. Box 1075, Pleasanton, CA 94566
Tel (925) 469-0417, Fax (925) 469-0462


DETERMINE 'G' FORCE PER PROJECT'S SPECIFIC:

S_{DS} = SPECTRAL ACCELERATION
(TYPICALLY AVAILABLE ON PROJECT STRUCTURE SHEET)

$F_p = 0.5 * S_{DS}$
(DEMAND 'G' FORCE)



EXAMPLE #1



EXAMPLE #2

NOTE: CONSTRUCTION SHALL NOT BEGIN UNTIL ALL SUBMITTALS ARE APPROVED.




A. PALMA
engineering
p.o. box 1075 pleasanton, ca 94566

PROJECT:
**SEISMIC SUSPENDED PDI
BUS SYSTEM SUPPORTS**


TAG:
SUPPORT GUIDELINES

SHEET:
DWG1

TRANSVERSE SEISMIC RESTRAINT SUSPENDED BUSRAIL



SEISMIC 'G'	SUPPORT SPACING
0.50G	40 FT. MAX.
0.75G	25 FT. MAX.
1.00G	20 FT. MAX.



NOTE: CONSTRUCTION SHALL NOT BEGIN UNTIL ALL SUBMITTALS ARE APPROVED.




A. PALMA
engineering
p.o. box 1075 pleasanton, ca 94566

PROJECT:
**SEISMIC SUSPENDED
BUS SYSTEM SUPPORTS**


TAG:
**HPW2-250-VH38-SM
[250A - 7 LB/FT]**

SHEET:
DWG2

ALL-DIRECTIONAL SEISMIC RESTRAINT SUSPENDED BUSRAIL



SEISMIC 'G'	SUPPORT SPACING
0.50G	80 FT. MAX.
0.75G	50 FT. MAX.
1.00G	40 FT. MAX.



NOTE: CONSTRUCTION SHALL NOT BEGIN UNTIL ALL SUBMITTALS ARE APPROVED.




A. PALMA
engineering
p.o. box 1075 pleasanton, ca 94566

PROJECT:
**SEISMIC SUSPENDED
BUS SYSTEM SUPPORTS**


TAG:
**HPW2-250-VH38-SM
[250A - 7 LB/FT]**

SHEET:
DWG3

TRANSVERSE SEISMIC RESTRAINT SUSPENDED BUSRAIL



SEISMIC 'G'	SUPPORT SPACING
0.50G	40 FT. MAX.
0.75G	25 FT. MAX.
1.00G	20 FT. MAX.



NOTE: CONSTRUCTION SHALL NOT BEGIN UNTIL ALL SUBMITTALS ARE APPROVED.




A. PALMA
engineering
p.o. box 1075 pleasanton, ca 94566

PROJECT:
**SEISMIC SUSPENDED
BUS SYSTEM SUPPORTS**


TAG:
**HPW2-400-VH38-SM
[250A - 10 LB/FT]**

SHEET:
DWG4

ALL-DIRECTIONAL SEISMIC RESTRAINT SUSPENDED BUSRAIL



SEISMIC 'G'	SUPPORT SPACING
0.50G	80 FT. MAX.
0.75G	50 FT. MAX.
1.00G	40 FT. MAX.



NOTE: CONSTRUCTION SHALL NOT BEGIN UNTIL ALL SUBMITTALS ARE APPROVED.




A. PALMA
engineering
p.o. box 1075 pleasanton, ca 94566

PROJECT:
**SEISMIC SUSPENDED
BUS SYSTEM SUPPORTS**


TAG:
**HPW2-400-VH38-SM
[250A - 10 LB/FT]**

SHEET:
DWG5

TRANSVERSE SEISMIC RESTRAINT SUSPENDED BUSRAIL



SEISMIC 'G'	SUPPORT SPACING
0.50G	20 FT. MAX.
0.75G	15 FT. MAX.
1.00G	15 FT. MAX.



NOTE: CONSTRUCTION SHALL NOT BEGIN UNTIL ALL SUBMITTALS ARE APPROVED.




A. PALMA
engineering
p.o. box 1075 pleasanton, ca 94566

PROJECT:
**SEISMIC SUSPENDED
BUS SYSTEM SUPPORTS**


TAG:
**HPW2-800-VH38-SM
[800A - 20 LB/FT]**

SHEET:
DWG6

ALL-DIRECTIONAL SEISMIC RESTRAINT SUSPENDED BUSRAIL



SEISMIC 'G'	SUPPORT SPACING
0.50G	40 FT. MAX.
0.75G	30 FT. MAX.
1.00G	30 FT. MAX.



NOTE: CONSTRUCTION SHALL NOT BEGIN UNTIL ALL SUBMITTALS ARE APPROVED.



A. PALMA
engineering
p.o. box 1075 pleasanton, ca 94566



PROJECT:
**SEISMIC SUSPENDED
BUS SYSTEM SUPPORTS**

TAG:
**HPW2-800-VH38-SM
[800A - 20 LB/FT]**

SHEET:
DWG7


UPPER STRUCTURE ATTACHMENT FOR SEISMIC HANGER

SEISMIC 'G'	250AMP SYSTEM	400AMP SYSTEM	800AMP SYSTEM
0.50G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.
0.75G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.
1.00G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	5/8"φ x 4 1/4" EMBED. *



HANGER ATTACHMENT TO (E) CONC. DECK

SEISMIC 'G'	250AMP SYSTEM	400AMP SYSTEM	800AMP SYSTEM
0.50G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.
0.75G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.
1.00G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.



HANGER ATTACHMENT TO (E) CONC. SLAB

NOTE: CONSTRUCTION SHALL NOT BEGIN UNTIL ALL SUBMITTALS ARE APPROVED.
STRUCTURAL ENGINEERING OF RECORD TO VERIFY ADEQUACY OF THE STRUCTURE FOR THE APPLIED LOAD.



A. PALMA
engineering
p.o. box 1075 pleasanton, ca 94566



PROJECT:
**SEISMIC SUSPENDED
BUS SYSTEM SUPPORTS**

TAG:
HANGER ANCHOR DETAILS

SHEET:
DWG8


UPPER STRUCTURE ATTACHMENT FOR SEISMIC BRACE

SEISMIC 'G'	250AMP SYSTEM	400AMP SYSTEM	800AMP SYSTEM
0.50G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.
0.75G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	5/8"φ x 4 1/4" EMBED. *
1.00G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	5/8"φ x 4 1/4" EMBED. *



BRACE ATTACHMENT TO (E) CONC. DECK

SEISMIC 'G'	250AMP SYSTEM	400AMP SYSTEM	800AMP SYSTEM
0.50G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.
0.75G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.
1.00G	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.	1/2"φ x 3/4" EMBED.



HANGER ATTACHMENT TO (E) CONC. SLAB

NOTE: CONSTRUCTION SHALL NOT BEGIN UNTIL ALL SUBMITTALS ARE APPROVED.
STRUCTURAL ENGINEERING OF RECORD TO VERIFY ADEQUACY OF THE STRUCTURE FOR THE APPLIED LOAD.



A. PALMA
engineering
p.o. box 1075 pleasanton, ca 94566

PROJECT:
**SEISMIC SUSPENDED
BUS SYSTEM SUPPORTS**

TAG:
BRACE ANCHOR DETAILS

SHEET:
DWG9

Customer: PDI, 4200 Oakleys Court,
Richmond, VA 23223
Date: 5/31/2017



Tag: Seismic Restraint Suspended
Bus System Supports
Building Code: 2012 IBC/2013
CBC&ASCE7-10

STRUCTURAL CALCULATIONS



DESIGN CRITERIA:

Governing Code: 2012 International Building Code /2013 California Building Code (CBC) & ASCE7-10

DESCRIPTION:

Substantiate suspended electrical bus system seismic load and dead weight. Members will be chosen to design at worst case load combination according to ASCE7 Chapter 2.

LOADING CRITERIA:

VERTICAL LOAD:

$L_s := 5 \cdot \text{ft}$	Maximum tributary length of support for dead load
$W_{250} := 7 \cdot \frac{\text{lb}}{\text{ft}}$	Max. weight for 250Amp bus system
$W_{400} := 10 \cdot \frac{\text{lb}}{\text{ft}}$	Max. weight for 400Amp bus system
$W_{800} := 20 \cdot \frac{\text{lb}}{\text{ft}}$	Max. weight for 800Amp bus system

SEISMIC LOAD:

Seismic demand per each different project can be determined through this equation:

$$F_p := \frac{0.4 \cdot a_p \cdot S_{DS}}{\frac{R_p}{I_p}} \cdot \left(1 + 2 \cdot \frac{z}{h} \right)^2 \quad \text{and can be simplify to this, } F_p := 0.50 \cdot S_{DS}$$

where, $z := 1$	Height in structure of point of attachment of component w/ respect to the base
$h := 1$	Average roof height of structure w/ respect to base
$I_p := 1.0$	Component importance factor
$a_p := 2.5$	Component amplification factor (ASCE7, table 13.6-1)
$R_p := 6.0$	Component response modification factor (ASCE7, table 13.6-1)
S_{DS}	Spectral acceleration, short period. (Per project's structure sheet or USGS Seismic Design Maps)

Let's assume seismic demand cateogorize into these three zone:

$F_{p1} := 0.50$	Seismic demand at 0.50G
$F_{p2} := 0.75$	Seismic demand at 0.75G
$F_{p3} := 1.00$	Seismic demand at 1.00G

SEISMIC DESIGN AT 0.50G:

converting Horizontal Seismic Force, F_{ph} , in allowable yields

$$F_{ph} := 0.7 \cdot F_{p1} = 0.35 \quad \text{ASCE7 Sect. 13.1.7, for ASD}$$

additional Vertical Seismic Force, F_{pv} , yields:

$$F_{pv} := 0.20$$

CHECK SEISMIC BRACE MEMBER:

REACTIONS:

$$\theta := 45 \cdot \text{deg} \quad \text{Allowable brace ratio angle (1:1 = 45.0°, 1.5:1 = 56.3°, 2:1 = 63.4°)}$$

$$N_{brT} := 1 \quad \text{Number of brace(s) in transverse direction}$$

$$N_{brL} := 1 \quad \text{Number of brace(s) in longitudinal direction}$$

For 250Amp & 400Amp bus system:

$$L_{t1} := 40 \cdot \text{ft} \quad \text{Maximum tributary length of support for transverse seismic}$$

$$L_{l1} := 80 \cdot \text{ft} \quad \text{Maximum tributary length of support for longitudinal seismic}$$

For 800Amp bus system:

$$L_{t2} := 20 \cdot \text{ft} \quad \text{Maximum tributary length of support for transverse seismic}$$

$$L_{l2} := 40 \cdot \text{ft} \quad \text{Maximum tributary length of support for longitudinal seismic}$$

Maximum brace compression in transverse direction

$$F_{brT1} := \frac{(F_{ph} \cdot W_{400}) \cdot L_{t1}}{N_{brT} \cdot \cos(\theta)} = 198 \text{ lb} \quad F_{brT2} := \frac{(F_{ph} \cdot W_{800}) \cdot L_{t2}}{N_{brT} \cdot \cos(\theta)} = 198 \text{ lb}$$

Maximum brace compression in longitudinal direction

$$F_{brL1} := \frac{(F_{ph} \cdot W_{400}) \cdot L_{l1}}{N_{brL} \cdot \cos(\theta)} = 396 \text{ lb} \quad F_{brL2} := \frac{(F_{ph} \cdot W_{800}) \cdot L_{l2}}{N_{brL} \cdot \cos(\theta)} = 396 \text{ lb}$$

COMPRESSION CHECK FOR SINGLE STRUT:

Unistrut P1000 Member designation

$L_{u2} := 120 \cdot \text{in}$ Unbraced length of member

$P_{allow} := 1380 \cdot \text{lb}$ Max. allowable load at slot face

$$F_{brL2} = 396 \text{ lb} \leq P_{allow} = 1380 \text{ lb} \quad \text{Okay!}$$

CHECK STRUT NUT CONNECTION:

3/8" Dia. Strut Nut Member designation

$V_{allow} := 800 \cdot \text{lb}$ Allowable resistance to slip

$N_{snut} := 1$ Number of strut nut(s)

$$F_{brT2} = 198 \text{ lb} \leq V_{allow} \cdot N_{snut} = 800 \text{ lb} \quad \text{Okay!}$$

CHECK HANGER ROD MEMBER:

MEMBER PHYSICAL PROPERTIES:

$d := 0.375 \cdot \text{in}$ Min. all-threaded rod member size

$N_{hr} := 1$ Number of hanger supporting busduct

CHECK FOR TENSION:

$T_{hrAllow} := 730 \cdot \text{lb}$ Allowable load per MSS SP-58

$$T_{rod} := \frac{W_{800} \cdot L_s + W_{800} \cdot L_s \cdot F_{pv}}{N_{hr}} + F_{brL2} \cdot \sin(\theta) = 400 \text{ lb} \leq T_{hrAllow} = 730 \text{ lb} \quad \text{Okay!}$$

CHECK FOR COMPRESSION FROM UPLIFT:

$$P_{rod} := \frac{W_{800} \cdot L_s + W_{800} \cdot L_s \cdot F_{pv}}{N_{hr}} - F_{brL2} \cdot \sin(\theta) = -160 \text{ lb}$$

Using AISC requirements for maximum allowable length and maximum allowable stress:

$$\frac{K \cdot L_{hr}}{r_{hr}} \leq 200 \quad \text{where,} \quad K := 1.0 \quad d = 0.375 \cdot \text{in} \quad r_{hr} := \frac{d}{4}$$

therefore, $L_{hr} := \frac{200 \cdot r_{hr}}{K} = 18.75 \cdot \text{in}$ (Maximum length allowed for hanger rod subjected to compression without stiffener)

Let stiffen hanger rod with 1-5/8"x12GA single channel with rod's clamp at $L_{u3} := 13 \cdot \text{in}$

Thus, $\frac{K \cdot L_{u3}}{r_{hr}} = 139$ where, $F_y := 36000 \frac{\text{lb}}{\text{in}^2}$ $E := 29000000 \cdot \frac{\text{lb}}{\text{in}^2}$ $A := 0.555 \cdot \text{in}^2$

$$F_e := \frac{\pi^2 \cdot E}{\left(\frac{K \cdot L_{u3}}{r_{hr}}\right)^2} = 14885 \cdot \frac{\text{lb}}{\text{in}^2}$$

$$\frac{K \cdot L_{u3}}{r_{hr}} = 139 > 4.71 \cdot \sqrt{\frac{E}{F_y}} = 134 \quad (\text{AISC Sect. 16.1, Chapt. E-3})$$

$$F_{cr} := 0.877 \cdot F_e = 13054 \cdot \frac{\text{lb}}{\text{in}^2}$$

$$P_n := F_{cr} \cdot A = 7245 \text{ lb}$$

CHECK FOR FAILURE:

$\Omega := 1.67$ Safety factor

$$|P_{rod}| = 160 \text{ lb} \leq \frac{P_n}{\Omega} = 4338 \text{ lb} \quad \text{Okay!}$$



CHECK SEISMIC ANCHOR ATTACHMENT TO CONCRETE STRUCTURE:

Per ASCE 13.4.2, Anchor's design force must carry 2.5 times the force in the component.

$$\Delta_{\text{conc}} := 2.5 \quad \text{Anchor design factor to concrete}$$

$$\Delta_{\text{lrfd}} := 0.7 \quad \text{ASD to LRFD}$$

ANCHOR REACTION(S) AT *SEISMIC BRACE* TO STRUCTURAL LOCATION:

$$\mathbf{T}_a := (\mathbf{F}_{\text{brL2}} \cdot \sin(\theta)) \cdot \left(\frac{\Delta_{\text{conc}}}{\Delta_{\text{lrfd}}} \right) = 1000 \text{ lb} \quad \text{Seismic brace anchor tension}$$

$$\mathbf{V}_a := (\mathbf{F}_{\text{brL2}} \cdot \cos(\theta)) \cdot \left(\frac{\Delta_{\text{conc}}}{\Delta_{\text{lrfd}}} \right) = 1000 \text{ lb} \quad \text{Seismic brace anchor shear}$$

Consider Powers Stud SD2 expansion anchor at 1/2" dia. with 3-1/4" min. effective embedment.

ANCHOR REACTION(S) AT *SEISMIC HANGER* TO STRUCTURAL LOCATION:


$$\mathbf{P}_o := \frac{\mathbf{W}_{800} \cdot \mathbf{L}_s + \mathbf{W}_{800} \cdot \mathbf{L}_s \cdot \mathbf{F}_{\text{pv}}}{\mathbf{N}_{\text{hr}}}$$

$$\mathbf{T}_{a2} := \mathbf{P}_o + \mathbf{T}_a = 1120 \text{ lb} \quad \text{Seismic hanger anchor tension}$$

Consider Powers Stud SD2 expansion anchor at 1/2" dia. with 3-1/4" min. effective embedment.


** Refer to attached Powers Design Assist for anchor specification and concrete break-out calculations.

GEOMETRY:




ANCHOR/ID	A	B	C	D	E	F	G
SCREW-BOLT+	3000	20	3.875	1.00	0.75	2.50	2.50
HANGER MATE+	3000	20	3.875	1.00	0.75	2.50	2.50
POWER-STUD+ SD1	3000	20	4.50	1.25	0.75	3.25	3.25
POWER-STUD+ SD2	3000	20	4.50	1.25	0.75	3.25	3.25
WEDGE-BOLT+	3000	20	4.50	1.25	0.75	3.25	3.25
SNAKE+	3000	20	4.50	1.25	1.00	3.00	3.00
VERTIGO+	3000	20	4.50	1.25	0.75	3.25	3.25
BANG-IT	2500	22	4.50	1.125	1.00	1.50	3.00
			3.875	0.75		1.50	3.00

ID	DESCRIPTION	ID	DESCRIPTION
A	CONCRETE MIN (PSI)	E	MIN COVER DISTANCE (IN)
B	MIN. STEEL GAGE NO.	F	MIN TOPPING THICKNESS LOWER FLUTE INSTALL (IN)
C	FLUTE WIDTH (IN)	G	MIN TOPPING THICKNESS UPPER FLUTE INSTALL (IN)
D	MIN FLUTE EDGE DISTANCE (IN) (LOWER FLUTE ONLY)		




LOAD ACTIONS: [lb], [ft-lb]



Design loads / actions		
N_u	1120	lb
V_{ux}	0	lb
V_{uy}	0	lb
M_{ux}	-	
M_{uy}	-	
M_{uz}	-	

Eccentric profile		
$e_x = 0.00$ inch; $e_y = 0.00$ inch		
Load reversal	100	%
X-direction		
Load reversal	100	%
Y-direction		

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines and must be checked for plausibility.



Company name: PDI

Project: Seismic HANGER Anchor

Date: 5/31/2017


Version: 2.4.6290.27783

Project number: Suspended Bus System

Page: 2/2

SUMMARY:

Selected anchor: Power-Stud+ SD2
 1/2" Ø; hnom 3-3/4" (95mm), Grade 2
 Effective embedment: $h_{ef} = 3.250$ inch
 Approval: ICC-ES ESR-2502



Basic principles of design:			
Design method:	ACI 318-11 (Appendix D)		
Concrete:	Sand-lightweight concrete	cracked concrete	$f'_c = 3000$ psi
Load combinations:	from Section 9.2 Factored loads $\Omega_0 =$ User enters load		
Anchor parameters:	$c_{min} = -$ inch	$s_{min} = -$ inch	$h_{min} = -$ inch
	$c_{ac} = 10.00$ inch	$s_{cr} = 9.75$ inch	Anchor ductility: yes
Reinforcement:	Tension: Condition B	Shear: Condition A	
Stand-off:	not existent		
Seismic loads:	yes		
	Tension load	yes (D.3.3.4.3(d))	
	Shear load	yes (D.3.3.5.3(c))	

Resulting anchor forces / load distribution:

Anchor No.	Tension load	Shear load
#1	1120 lb	0 lb
Maximum	1120 lb	0 lb


Max. concrete compression strain: 0.00 ‰
 Max. concrete compression stress: 0 psi
 Resulting tension force: 0 lb
 Resulting compression force: 0 lb

Calculations:	Design proof:	Demand	Capacity	Status
	Tension load	1120 lb	1268 lb	$0.88 \leq 1.0$
	Shear load	-	-	OK
	Interaction	-	-	

Anchor plate: Material: $f_{yk} = 36000$ psi
 Length x width: 8.00 inch x 8.00 inch
 Actual plate thickness: 0.394 inch
 Calculated plate thickness: - inch not calculated


Profile: none selected

GEOMETRY:




ANCHOR/ID	A	B	C	D	E	F	G
SCREW-BOLT+	3000	20	3.875	1.00	0.75	2.50	2.50
HANGER MATE+	3000	20	3.875	1.00	0.75	2.50	2.50
POWER-STUD+ SD1	3000	20	4.50	1.25	0.75	3.25	3.25
POWER-STUD+ SD2	3000	20	4.50	1.25	0.75	3.25	3.25
WEDGE-BOLT+	3000	20	4.50	1.25	0.75	3.25	3.25
SNAKE+	3000	20	4.50	1.25	1.00	3.00	3.00
VERTIGO+	3000	20	4.50	1.25	0.75	3.25	3.25
BANG-IT	2500	22	4.50	1.125	1.00	1.50	3.00
			3.875	0.75		1.50	3.00

ID	DESCRIPTION	ID	DESCRIPTION
A	CONCRETE MIN (PSI)	E	MIN COVER DISTANCE (IN)
B	MIN. STEEL GAGE NO.	F	MIN TOPPING THICKNESS LOWER FLUTE INSTALL (IN)
C	FLUTE WIDTH (IN)	G	MIN TOPPING THICKNESS UPPER FLUTE INSTALL (IN)
D	MIN FLUTE EDGE DISTANCE (IN) (LOWER FLUTE ONLY)		




LOAD ACTIONS: [lb], [ft-lb]



Design loads / actions		
N_u	1000	lb
V_{ux}	0	lb
V_{uy}	1000	lb
M_{ux}	-	
M_{uy}	-	
M_{uz}	-	

Eccentric profile		
$e_x = 0.00$ inch; $e_y = 0.00$ inch		
Load reversal	100	%
X-direction		
Load reversal	100	%
Y-direction		

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines and must be checked for plausibility.



Company name: PDI

Project: Seismic BRACE Anchor

Date: 5/31/2017


Version: 2.4.6290.27783

Project number: Suspended Bus System

Page: 2/2

SUMMARY:

Selected anchor: Power-Stud+ SD2
 1/2" Ø; hnom 3-3/4" (95mm), Grade 2
 Effective embedment: $h_{ef} = 3.250$ inch
 Approval: ICC-ES ESR-2502



Basic principles of design:

Design method: ACI 318-11 (Appendix D)
 Concrete: Sand-lightweight concrete cracked concrete $f'_c = 3000$ psi
 Load combinations: from Section 9.2
 Factored loads
 $\Omega_0 =$ User enters load
 Anchor parameters: $c_{min} = -$ inch $s_{min} = -$ inch $h_{min} = -$ inch
 $c_{ac} = 10.00$ inch $s_{cr} = 9.75$ inch Anchor ductility: yes
 Reinforcement: Tension: Condition B Shear: Condition A
 Stand-off: not existent
 Seismic loads: yes
 Tension load yes (D.3.3.4.3(d))
 Shear load yes (D.3.3.5.3(c))

Resulting anchor forces / load distribution:

Anchor No.	Tension load	Shear load
#1	1000 lb	1000 lb
Maximum	1000 lb	1000 lb

Max. concrete compression strain: 0.00 ‰
 Max. concrete compression stress: 0 psi
 Resulting tension force: 0 lb
 Resulting compression force: 0 lb

Calculations:	Design proof:	Demand	Capacity	Status
	Tension load	1000 lb	1268 lb	$0.79 \leq 1.0$
	Shear load	1000 lb	3276 lb	$0.31 \leq 1.0$
	Interaction	-	-	$0.91 \leq 1.0$

OK

Anchor plate: Material: $f_{yk} = 36000$ psi
 Length x width: 8.00 inch x 8.00 inch
 Actual plate thickness: 0.394 inch
 Calculated plate thickness: - inch not calculated

Profile: none selected

SEISMIC DESIGN AT 0.75G:

converting Horizontal Seismic Force, F_{ph} , in allowable yields

$$F_{ph} := 0.7 \cdot F_{p2} = 0.53 \quad \text{ASCE7 Sect. 13.1.7, for ASD}$$

additional Vertical Seismic Force, F_{pv} , yields:

$$F_{pv} := 0.20$$

CHECK SEISMIC BRACE MEMBER:

REACTIONS:

$$\theta := 45 \cdot \text{deg} \quad \text{Allowable brace ratio angle (1:1 = 45.0°, 1.5:1 = 56.3°, 2:1 = 63.4°)}$$

$$N_{brT} := 1 \quad \text{Number of brace(s) in transverse direction}$$

$$N_{brL} := 1 \quad \text{Number of brace(s) in longitudinal direction}$$

For 250Amp & 400Amp bus system:

$$L_{t1} := 25 \cdot \text{ft} \quad \text{Maximum tributary length of support for transverse seismic}$$

$$L_{l1} := 50 \cdot \text{ft} \quad \text{Maximum tributary length of support for longitudinal seismic}$$

For 800Amp bus system:

$$L_{t2} := 15 \cdot \text{ft} \quad \text{Maximum tributary length of support for transverse seismic}$$

$$L_{l2} := 30 \cdot \text{ft} \quad \text{Maximum tributary length of support for longitudinal seismic}$$

Maximum brace compression in transverse direction

$$F_{brT1} := \frac{(F_{ph} \cdot W_{400}) \cdot L_{t1}}{N_{brT} \cdot \cos(\theta)} = 186 \text{ lb} \quad F_{brT2} := \frac{(F_{ph} \cdot W_{800}) \cdot L_{t2}}{N_{brT} \cdot \cos(\theta)} = 223 \text{ lb}$$

Maximum brace compression in longitudinal direction

$$F_{brL1} := \frac{(F_{ph} \cdot W_{400}) \cdot L_{l1}}{N_{brL} \cdot \cos(\theta)} = 371 \text{ lb} \quad F_{brL2} := \frac{(F_{ph} \cdot W_{800}) \cdot L_{l2}}{N_{brL} \cdot \cos(\theta)} = 445 \text{ lb}$$

COMPRESSION CHECK FOR SINGLE STRUT:

Unistrut P1000 Member designation

$L_{u2} := 120 \cdot \text{in}$ Unbraced length of member

$P_{allow} := 1380 \cdot \text{lb}$ Max. allowable load at slot face

$$F_{brL2} = 445 \text{ lb} \leq P_{allow} = 1380 \text{ lb} \quad \text{Okay!}$$

CHECK STRUT NUT CONNECTION:

3/8" Dia. Strut Nut Member designation

$V_{allow} := 800 \cdot \text{lb}$ Allowable resistance to slip

$N_{snut} := 1$ Number of strut nut(s)

$$F_{brT2} = 223 \text{ lb} \leq V_{allow} \cdot N_{snut} = 800 \text{ lb} \quad \text{Okay!}$$

CHECK HANGER ROD MEMBER:

MEMBER PHYSICAL PROPERTIES:

$d := 0.375 \cdot \text{in}$ Min. all-threaded rod member size
 $N_{hr} := 1$ Number of hanger supporting busduct

CHECK FOR TENSION:

$T_{hrAllow} := 730 \cdot \text{lb}$ Allowable load per MSS SP-58

$$T_{rod} := \frac{W_{800} \cdot L_s + W_{800} \cdot L_s \cdot F_{pv}}{N_{hr}} + F_{brL2} \cdot \sin(\theta) = 435 \text{ lb} \leq T_{hrAllow} = 730 \text{ lb} \quad \text{Okay!}$$

CHECK FOR COMPRESSION FROM UPLIFT:

$$P_{rod} := \frac{W_{800} \cdot L_s + W_{800} \cdot L_s \cdot F_{pv}}{N_{hr}} - F_{brL2} \cdot \sin(\theta) = -195 \text{ lb}$$

Using AISC requirements for maximum allowable length and maximum allowable stress:

$$\frac{K \cdot L_{hr}}{r_{hr}} \leq 200 \quad \text{where,} \quad K := 1.0 \quad d = 0.375 \cdot \text{in} \quad r_{hr} := \frac{d}{4}$$

therefore, $L_{hr} := \frac{200 \cdot r_{hr}}{K} = 18.75 \cdot \text{in}$ (Maximum length allowed for hanger rod subjected to compression without stiffener)

Let stiffen hanger rod with 1-5/8"x12GA single channel with rod's clamp at $L_{u3} := 13 \cdot \text{in}$

$$\text{Thus, } \frac{K \cdot L_{u3}}{r_{hr}} = 139 \quad \text{where,} \quad F_y := 36000 \frac{\text{lb}}{\text{in}^2} \quad E := 29000000 \cdot \frac{\text{lb}}{\text{in}^2} \quad A := 0.555 \cdot \text{in}^2$$

$$F_e := \frac{\pi^2 \cdot E}{\left(\frac{K \cdot L_{u3}}{r_{hr}}\right)^2} = 14885 \cdot \frac{\text{lb}}{\text{in}^2}$$

$$\frac{K \cdot L_{u3}}{r_{hr}} = 139 > 4.71 \cdot \sqrt{\frac{E}{F_y}} = 134 \quad (\text{AISC Sect. 16.1, Chapt. E-3})$$

$$F_{cr} := 0.877 \cdot F_e = 13054 \cdot \frac{\text{lb}}{\text{in}^2}$$

$$P_n := F_{cr} \cdot A = 7245 \text{ lb}$$

CHECK FOR FAILURE:

$\Omega := 1.67$ Safety factor

$$|P_{rod}| = 195 \text{ lb} \leq \frac{P_n}{\Omega} = 4338 \text{ lb} \quad \text{Okay!}$$



CHECK SEISMIC ANCHOR ATTACHMENT TO CONCRETE STRUCTURE:

Per ASCE 13.4.2, Anchor's design force must carry 2.5 times the force in the component.

$$\Delta_{\text{conc}} := 2.5 \quad \text{Anchor design factor to concrete}$$

$$\Delta_{\text{lrfd}} := 0.7 \quad \text{ASD to LRFD}$$

ANCHOR REACTION(S) AT *SEISMIC BRACE* TO STRUCTURAL LOCATION:

$$\mathbf{T}_a := (\mathbf{F}_{\text{brL2}} \cdot \sin(\theta)) \cdot \left(\frac{\Delta_{\text{conc}}}{\Delta_{\text{lrfd}}} \right) = 1125 \text{ lb} \quad \text{Seismic brace anchor tension}$$

$$\mathbf{V}_a := (\mathbf{F}_{\text{brL2}} \cdot \cos(\theta)) \cdot \left(\frac{\Delta_{\text{conc}}}{\Delta_{\text{lrfd}}} \right) = 1125 \text{ lb} \quad \text{Seismic brace anchor shear}$$

Consider Powers Stud SD2 expansion anchor at 5/8" dia. with 4-1/4" min. effective embedment.

ANCHOR REACTION(S) AT *SEISMIC HANGER* TO STRUCTURAL LOCATION:


$$\mathbf{P}_o := \frac{\mathbf{W}_{800} \cdot \mathbf{L}_s + \mathbf{W}_{800} \cdot \mathbf{L}_s \cdot \mathbf{F}_{\text{pv}}}{\mathbf{N}_{\text{hr}}}$$

$$\mathbf{T}_{a2} := \mathbf{P}_o + \mathbf{T}_a = 1245 \text{ lb} \quad \text{Seismic hanger anchor tension}$$

Consider Powers Stud SD2 expansion anchor at 1/2" dia. with 3-1/4" min. effective embedment.


** Refer to attached Powers Design Assist for anchor specification and concrete break-out calculations.

GEOMETRY:




ANCHOR/ID	A	B	C	D	E	F	G
SCREW-BOLT+	3000	20	3.875	1.00	0.75	2.50	2.50
HANGER MATE+	3000	20	3.875	1.00	0.75	2.50	2.50
POWER-STUD+ SD1	3000	20	4.50	1.25	0.75	3.25	3.25
POWER-STUD+ SD2	3000	20	4.50	1.25	0.75	3.25	3.25
WEDGE-BOLT+	3000	20	4.50	1.25	0.75	3.25	3.25
SNAKE+	3000	20	4.50	1.25	1.00	3.00	3.00
VERTIGO+	3000	20	4.50	1.25	0.75	3.25	3.25
BANG-IT	2500	22	4.50	1.125	1.00	1.50	3.00
			3.875	0.75		1.50	3.00

ID	DESCRIPTION	ID	DESCRIPTION
A	CONCRETE MIN (PSI)	E	MIN COVER DISTANCE (IN)
B	MIN. STEEL GAGE NO.	F	MIN TOPPING THICKNESS LOWER FLUTE INSTALL (IN)
C	FLUTE WIDTH (IN)	G	MIN TOPPING THICKNESS UPPER FLUTE INSTALL (IN)
D	MIN FLUTE EDGE DISTANCE (IN) (LOWER FLUTE ONLY)		



LOAD ACTIONS: [lb], [ft-lb]



Design loads / actions		
N_u	1245	lb
V_{ux}	0	lb
V_{uy}	0	lb
M_{ux}	-	
M_{uy}	-	
M_{uz}	-	

Eccentric profile		
$e_x = 0.00$ inch; $e_y = 0.00$ inch		
Load reversal	100	%
X-direction		
Load reversal	100	%
Y-direction		

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines and must be checked for plausibility.



Company name: PDI

Project: Seismic HANGER Anchor

Date: 5/31/2017


Version: 2.4.6290.27783

Project number: Suspended Bus System

Page: 2/2

SUMMARY:

Selected anchor: Power-Stud+ SD2
 1/2" Ø; hnom 3-3/4" (95mm), Grade 2
 Effective embedment: $h_{ef} = 3.250$ inch
 Approval: ICC-ES ESR-2502



Basic principles of design:			
Design method:	ACI 318-11 (Appendix D)		
Concrete:	Sand-lightweight concrete	cracked concrete	$f'_c = 3000$ psi
Load combinations:	from Section 9.2 Factored loads $\Omega_0 =$ User enters load		
Anchor parameters:	$c_{min} = -$ inch	$s_{min} = -$ inch	$h_{min} = -$ inch
	$c_{ac} = 10.00$ inch	$s_{cr} = 9.75$ inch	Anchor ductility: yes
Reinforcement:	Tension: Condition B	Shear: Condition A	
Stand-off:	not existent		
Seismic loads:	yes		
	Tension load	yes (D.3.3.4.3(d))	
	Shear load	yes (D.3.3.5.3(c))	

Resulting anchor forces / load distribution:

Anchor No.	Tension load	Shear load
#1	1245 lb	0 lb
Maximum	1245 lb	0 lb


Max. concrete compression strain: 0.00 ‰
 Max. concrete compression stress: 0 psi
 Resulting tension force: 0 lb
 Resulting compression force: 0 lb

Calculations:	Design proof:	Demand	Capacity	Status
	Tension load	1245 lb	1268 lb	$0.98 \leq 1.0$
	Shear load	-	-	OK
	Interaction	-	-	

Anchor plate: Material: $f_{yk} = 36000$ psi
 Length x width: 8.00 inch x 8.00 inch
 Actual plate thickness: 0.394 inch
 Calculated plate thickness: - inch not calculated


Profile: none selected

GEOMETRY:




ANCHOR/ID	A	B	C	D	E	F	G
SCREW-BOLT+	3000	20	3.875	1.00	0.75	2.50	2.50
HANGER MATE+	3000	20	3.875	1.00	0.75	2.50	2.50
POWER-STUD+ SD1	3000	20	4.50	1.25	0.75	3.25	3.25
POWER-STUD+ SD2	3000	20	4.50	1.25	0.75	3.25	3.25
WEDGE-BOLT+	3000	20	4.50	1.25	0.75	3.25	3.25
SNAKE+	3000	20	4.50	1.25	1.00	3.00	3.00
VERTIGO+	3000	20	4.50	1.25	0.75	3.25	3.25
BANG-IT	2500	22	4.50	1.125	1.00	1.50	3.00
			3.875	0.75		1.50	3.00

ID	DESCRIPTION	ID	DESCRIPTION
A	CONCRETE MIN (PSI)	E	MIN COVER DISTANCE (IN)
B	MIN. STEEL GAGE NO.	F	MIN TOPPING THICKNESS LOWER FLUTE INSTALL (IN)
C	FLUTE WIDTH (IN)	G	MIN TOPPING THICKNESS UPPER FLUTE INSTALL (IN)
D	MIN FLUTE EDGE DISTANCE (IN) (LOWER FLUTE ONLY)		




LOAD ACTIONS: [lb], [ft-lb]



Design loads / actions		
N_u	1125	lb
V_{ux}	0	lb
V_{uy}	1125	lb
M_{ux}	-	
M_{uy}	-	
M_{uz}	-	

Eccentric profile		
$e_x = 0.00$ inch; $e_y = 0.00$ inch		
Load reversal	100	%
X-direction		
Load reversal	100	%
Y-direction		

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines and must be checked for plausibility.



Company name: PDI

Project: Seismic BRACE Anchor

Date: 5/31/2017


Version: 2.4.6290.27783

Project number: Suspended Bus System

Page: 2/2

SUMMARY:

Selected anchor: Power-Stud+ SD2
 5/8" Ø; hnom 4-7/8" (124mm), Grade 2
 Effective embedment: $h_{ef} = 4.250$ inch
 Approval: ICC-ES ESR-2502



Basic principles of design:

Design method: ACI 318-11 (Appendix D)
 Concrete: Sand-lightweight concrete cracked concrete $f'_c = 3000$ psi
 Load combinations: from Section 9.2
 Factored loads
 $\Omega_0 =$ User enters load
 Anchor parameters: $c_{min} = -$ inch $s_{min} = -$ inch $h_{min} = -$ inch
 $c_{ac} = 10.00$ inch $s_{cr} = 12.75$ inch Anchor ductility: yes
 Reinforcement: Tension: Condition B Shear: Condition A
 Stand-off: not existent
 Seismic loads: yes
 Tension load yes (D.3.3.4.3(d))
 Shear load yes (D.3.3.5.3(c))

Resulting anchor forces / load distribution:

Anchor No.	Tension load	Shear load
#1	1125 lb	1125 lb
Maximum	1125 lb	1125 lb

Max. concrete compression strain: 0.00 ‰
 Max. concrete compression stress: 0 psi
 Resulting tension force: 0 lb
 Resulting compression force: 0 lb

Calculations:	Design proof:	Demand	Capacity	Status
	Tension load	1125 lb	2542 lb	$0.44 \leq 1.0$
	Shear load	1125 lb	2889 lb	$0.39 \leq 1.0$
	Interaction	-	-	$0.69 \leq 1.0$

OK

Anchor plate: Material: $f_{yk} = 36000$ psi
 Length x width: 8.00 inch x 8.00 inch
 Actual plate thickness: 0.394 inch
 Calculated plate thickness: - inch not calculated

Profile: none selected

SEISMIC DESIGN AT 1.00G:

converting Horizontal Seismic Force, F_{ph} , in allowable yields

$$F_{ph} := 0.7 \cdot F_{p3} = 0.70 \quad \text{ASCE7 Sect. 13.1.7, for ASD}$$

additional Vertical Seismic Force, F_{pv} , yields:

$$F_{pv} := 0.20$$

CHECK SEISMIC BRACE MEMBER:

REACTIONS:

$$\theta := 45 \cdot \text{deg} \quad \text{Allowable brace ratio angle (1:1 = 45.0°, 1.5:1 = 56.3°, 2:1 = 63.4°)}$$

$$N_{brT} := 1 \quad \text{Number of brace(s) in transverse direction}$$

$$N_{brL} := 1 \quad \text{Number of brace(s) in longitudinal direction}$$

For 250Amp & 400Amp bus system:

$$L_{t1} := 20 \cdot \text{ft} \quad \text{Maximum tributary length of support for transverse seismic}$$

$$L_{l1} := 40 \cdot \text{ft} \quad \text{Maximum tributary length of support for longitudinal seismic}$$

For 800Amp bus system:

$$L_{t2} := 15 \cdot \text{ft} \quad \text{Maximum tributary length of support for transverse seismic}$$

$$L_{l2} := 30 \cdot \text{ft} \quad \text{Maximum tributary length of support for longitudinal seismic}$$

Maximum brace compression in transverse direction

$$F_{brT1} := \frac{(F_{ph} \cdot W_{400}) \cdot L_{t1}}{N_{brT} \cdot \cos(\theta)} = 198 \text{ lb} \quad F_{brT2} := \frac{(F_{ph} \cdot W_{800}) \cdot L_{t2}}{N_{brT} \cdot \cos(\theta)} = 297 \text{ lb}$$

Maximum brace compression in longitudinal direction

$$F_{brL1} := \frac{(F_{ph} \cdot W_{400}) \cdot L_{l1}}{N_{brL} \cdot \cos(\theta)} = 396 \text{ lb} \quad F_{brL2} := \frac{(F_{ph} \cdot W_{800}) \cdot L_{l2}}{N_{brL} \cdot \cos(\theta)} = 594 \text{ lb}$$

COMPRESSION CHECK FOR SINGLE STRUT:

Unistrut P1000 Member designation

$L_{u2} := 120 \cdot \text{in}$ Unbraced length of member

$P_{allow} := 1380 \cdot \text{lb}$ Max. allowable load at slot face

$$F_{brL2} = 594 \text{ lb} \leq P_{allow} = 1380 \text{ lb} \quad \text{Okay!}$$

CHECK STRUT NUT CONNECTION:

3/8" Dia. Strut Nut Member designation

$V_{allow} := 800 \cdot \text{lb}$ Allowable resistance to slip

$N_{snut} := 1$ Number of strut nut(s)

$$F_{brT2} = 297 \text{ lb} \leq V_{allow} \cdot N_{snut} = 800 \text{ lb} \quad \text{Okay!}$$

CHECK HANGER ROD MEMBER:

MEMBER PHYSICAL PROPERTIES:

$d := 0.375 \cdot \text{in}$ Min. all-threaded rod member size

$N_{hr} := 1$ Number of hanger supporting busduct

CHECK FOR TENSION:

$T_{hrAllow} := 730 \cdot \text{lb}$ Allowable load per MSS SP-58

$$T_{rod} := \frac{W_{800} \cdot L_s + W_{800} \cdot L_s \cdot F_{pv}}{N_{hr}} + F_{brL2} \cdot \sin(\theta) = 540 \text{ lb} \leq T_{hrAllow} = 730 \text{ lb} \quad \text{Okay!}$$

CHECK FOR COMPRESSION FROM UPLIFT:

$$P_{rod} := \frac{W_{800} \cdot L_s + W_{800} \cdot L_s \cdot F_{pv}}{N_{hr}} - F_{brL2} \cdot \sin(\theta) = -300 \text{ lb}$$

Using AISC requirements for maximum allowable length and maximum allowable stress:

$$\frac{K \cdot L_{hr}}{r_{hr}} \leq 200 \quad \text{where,} \quad K := 1.0 \quad d = 0.375 \cdot \text{in} \quad r_{hr} := \frac{d}{4}$$

therefore, $L_{hr} := \frac{200 \cdot r_{hr}}{K} = 18.75 \cdot \text{in}$ (Maximum length allowed for hanger rod subjected to compression without stiffener)

Let stiffen hanger rod with 1-5/8"x12GA single channel with rod's clamp at $L_{u3} := 13 \cdot \text{in}$

Thus, $\frac{K \cdot L_{u3}}{r_{hr}} = 139$ where, $F_y := 36000 \frac{\text{lb}}{\text{in}^2}$ $E := 29000000 \cdot \frac{\text{lb}}{\text{in}^2}$ $A := 0.555 \cdot \text{in}^2$

$$F_e := \frac{\pi^2 \cdot E}{\left(\frac{K \cdot L_{u3}}{r_{hr}}\right)^2} = 14885 \cdot \frac{\text{lb}}{\text{in}^2}$$

$$\frac{K \cdot L_{u3}}{r_{hr}} = 139 > 4.71 \cdot \sqrt{\frac{E}{F_y}} = 134 \quad (\text{AISC Sect. 16.1, Chapt. E-3})$$

$$F_{cr} := 0.877 \cdot F_e = 13054 \cdot \frac{\text{lb}}{\text{in}^2}$$

$$P_n := F_{cr} \cdot A = 7245 \text{ lb}$$

CHECK FOR FAILURE:

$\Omega := 1.67$ Safety factor

$$|P_{rod}| = 300 \text{ lb} \leq \frac{P_n}{\Omega} = 4338 \text{ lb} \quad \text{Okay!}$$

CHECK SEISMIC ANCHOR ATTACHMENT TO CONCRETE STRUCTURE:

Per ASCE 13.4.2, Anchor's design force must carry 2.5 times the force in the component.

$$\Delta_{\text{conc}} := 2.5 \quad \text{Anchor design factor to concrete}$$

$$\Delta_{\text{lrfd}} := 0.7 \quad \text{ASD to LRFD}$$

ANCHOR REACTION(S) AT *SEISMIC BRACE* TO STRUCTURAL LOCATION:

$$\mathbf{T}_a := (\mathbf{F}_{\text{brL2}} \cdot \sin(\theta)) \cdot \left(\frac{\Delta_{\text{conc}}}{\Delta_{\text{lrfd}}} \right) = 1500 \text{ lb} \quad \text{Seismic brace anchor tension}$$

$$\mathbf{V}_a := (\mathbf{F}_{\text{brL2}} \cdot \cos(\theta)) \cdot \left(\frac{\Delta_{\text{conc}}}{\Delta_{\text{lrfd}}} \right) = 1500 \text{ lb} \quad \text{Seismic brace anchor shear}$$

Consider Powers Stud SD2 expansion anchor at 5/8" dia. with 4-1/4" min. effective embedment.

ANCHOR REACTION(S) AT *SEISMIC HANGER* TO STRUCTURAL LOCATION:


$$\mathbf{P}_o := \frac{\mathbf{W}_{800} \cdot \mathbf{L}_s + \mathbf{W}_{800} \cdot \mathbf{L}_s \cdot \mathbf{F}_{\text{pv}}}{\mathbf{N}_{\text{hr}}}$$

$$\mathbf{T}_{a2} := \mathbf{P}_o + \mathbf{T}_a = 1620 \text{ lb} \quad \text{Seismic hanger anchor tension}$$

Consider Powers Stud SD2 expansion anchor at 5/8" dia. with 4-1/4" min. effective embedment.


** Refer to attached Powers Design Assist for anchor specification and concrete break-out calculations.

GEOMETRY:




ANCHOR/ID	A	B	C	D	E	F	G
SCREW-BOLT+	3000	20	3.875	1.00	0.75	2.50	2.50
HANGER MATE+	3000	20	3.875	1.00	0.75	2.50	2.50
POWER-STUD+ SD1	3000	20	4.50	1.25	0.75	3.25	3.25
POWER-STUD+ SD2	3000	20	4.50	1.25	0.75	3.25	3.25
WEDGE-BOLT+	3000	20	4.50	1.25	0.75	3.25	3.25
SNAKE+	3000	20	4.50	1.25	1.00	3.00	3.00
VERTIGO+	3000	20	4.50	1.25	0.75	3.25	3.25
BANG-IT	2500	22	4.50	1.125	1.00	1.50	3.00
			3.875	0.75		1.50	3.00

ID	DESCRIPTION	ID	DESCRIPTION
A	CONCRETE MIN (PSI)	E	MIN COVER DISTANCE (IN)
B	MIN. STEEL GAGE NO.	F	MIN TOPPING THICKNESS LOWER FLUTE INSTALL (IN)
C	FLUTE WIDTH (IN)	G	MIN TOPPING THICKNESS UPPER FLUTE INSTALL (IN)
D	MIN FLUTE EDGE DISTANCE (IN) (LOWER FLUTE ONLY)		



LOAD ACTIONS: [lb], [ft-lb]



Design loads / actions		
N_u	1620	lb
V_{ux}	0	lb
V_{uy}	0	lb
M_{ux}	-	
M_{uy}	-	
M_{uz}	-	

Eccentric profile		
$e_x = 0.00$ inch; $e_y = 0.00$ inch		
Load reversal	100	%
X-direction		
Load reversal	100	%
Y-direction		

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines and must be checked for plausibility.



Company name: PDI

Project: Seismic HANGER Anchor

Date: 5/31/2017


Version: 2.4.6290.27783

Project number: Suspended Bus System

Page: 2/2

SUMMARY:

Selected anchor: Power-Stud+ SD2
 5/8" Ø; hnom 4-7/8" (124mm), Grade 2
 Effective embedment: $h_{ef} = 4.250$ inch
 Approval: ICC-ES ESR-2502



Basic principles of design:			
Design method:	ACI 318-11 (Appendix D)		
Concrete:	Sand-lightweight concrete	cracked concrete	$f'_c = 3000$ psi
Load combinations:	from Section 9.2 Factored loads $\Omega_0 =$ User enters load		
Anchor parameters:	$c_{min} = -$ inch	$s_{min} = -$ inch	$h_{min} = -$ inch
	$c_{ac} = 10.00$ inch	$s_{cr} = 12.75$ inch	Anchor ductility: yes
Reinforcement:	Tension: Condition B	Shear: Condition A	
Stand-off:	not existent		
Seismic loads:	yes		
	Tension load	yes (D.3.3.4.3(d))	
	Shear load	yes (D.3.3.5.3(c))	

Resulting anchor forces / load distribution:

Anchor No.	Tension load	Shear load
#1	1620 lb	0 lb
Maximum	1620 lb	0 lb


Max. concrete compression strain: 0.00 ‰
 Max. concrete compression stress: 0 psi
 Resulting tension force: 0 lb
 Resulting compression force: 0 lb

Calculations:	Design proof:	Demand	Capacity	Status
	Tension load	1620 lb	2542 lb	$0.64 \leq 1.0$
	Shear load	-	-	OK
	Interaction	-	-	

Anchor plate: Material: $f_{yk} = 36000$ psi
 Length x width: 8.00 inch x 8.00 inch
 Actual plate thickness: 0.394 inch
 Calculated plate thickness: - inch not calculated


Profile: none selected

GEOMETRY:




ANCHOR/ID	A	B	C	D	E	F	G
SCREW-BOLT+	3000	20	3.875	1.00	0.75	2.50	2.50
HANGER MATE+	3000	20	3.875	1.00	0.75	2.50	2.50
POWER-STUD+ SD1	3000	20	4.50	1.25	0.75	3.25	3.25
POWER-STUD+ SD2	3000	20	4.50	1.25	0.75	3.25	3.25
WEDGE-BOLT+	3000	20	4.50	1.25	0.75	3.25	3.25
SNAKE+	3000	20	4.50	1.25	1.00	3.00	3.00
VERTIGO+	3000	20	4.50	1.25	0.75	3.25	3.25
BANG-IT	2500	22	4.50	1.125	1.00	1.50	3.00
			3.875	0.75		1.50	3.00

ID	DESCRIPTION	ID	DESCRIPTION
A	CONCRETE MIN (PSI)	E	MIN COVER DISTANCE (IN)
B	MIN. STEEL GAGE NO.	F	MIN TOPPING THICKNESS LOWER FLUTE INSTALL (IN)
C	FLUTE WIDTH (IN)	G	MIN TOPPING THICKNESS UPPER FLUTE INSTALL (IN)
D	MIN FLUTE EDGE DISTANCE (IN) (LOWER FLUTE ONLY)		




LOAD ACTIONS: [lb], [ft-lb]



Design loads / actions		
N_y	1500	lb
V_{ux}	0	lb
V_{uy}	1500	lb
M_{ux}	-	
M_{uy}	-	
M_{uz}	-	

Eccentric profile		
$e_x = 0.00$ inch; $e_y = 0.00$ inch		
Load reversal	100	%
X-direction		
Load reversal	100	%
Y-direction		

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines and must be checked for plausibility.



Company name: PDI

Project: Seismic BRACE Anchor

Date: 5/31/2017


Version: 2.4.6290.27783

Project number: Suspended Bus System

Page: 2/2

SUMMARY:

Selected anchor: Power-Stud+ SD2
 5/8" Ø; hnom 4-7/8" (124mm), Grade 2
 Effective embedment: h_{ef} = 4.250 inch
 Approval: ICC-ES ESR-2502



Basic principles of design:			
Design method:	ACI 318-11 (Appendix D)		
Concrete:	Sand-lightweight concrete	cracked concrete	f' _c = 3000 psi
Load combinations:	from Section 9.2 Factored loads Ω ₀ = User enters load		
Anchor parameters:	c _{min} = - inch	s _{min} = - inch	h _{min} = - inch
	c _{ac} = 10.00 inch	s _{cr} = 12.75 inch	Anchor ductility: yes
Reinforcement:	Tension: Condition B	Shear: Condition A	
Stand-off:	not existent		
Seismic loads:	yes		
	Tension load	yes (D.3.3.4.3(d))	
	Shear load	yes (D.3.3.5.3(c))	

Resulting anchor forces / load distribution:

Anchor No.	Tension load	Shear load
#1	1500 lb	1500 lb
Maximum	1500 lb	1500 lb

Max. concrete compression strain: 0.00 ‰
 Max. concrete compression stress: 0 psi
 Resulting tension force: 0 lb
 Resulting compression force: 0 lb

Calculations:	Design proof:	Demand	Capacity	Status
	Tension load	1500 lb	2542 lb	0.59 ≤ 1.0
	Shear load	1500 lb	2889 lb	0.52 ≤ 1.0
	Interaction	-	-	0.92 ≤ 1.0

Anchor plate:
 Material: f_{yk} = 36000 psi
 Length x width: 8.00 inch x 8.00 inch
 Actual plate thickness: 0.394 inch
 Calculated plate thickness: - inch not calculated

Profile: none selected